

IOC - LCR

IOC - LCR by EPA Methods 200.9, 200.7

Distribution System - Report of Analysis

IOC - LCR	Group: A
System ID No: 72810M	System Name: Riverhill Homeowners Asse
DOH Source No: 93	County: Mason
Sample Purpose: C	Date Received: 6/30/2008
	Date Analyzed: 7/10/2008
	Date Reported: 7/15/2008
Send Report To: Ken Loomis P.O. Box 86 Belfair, WA 98528	Bill To:

DOH #	Lead, mg/L	Copper, mg/L
SRL, mg/L	0.001	0.02
Trigger Level, mg/L	--	--
MCL, mg/L	*	*
Analytical Method (Analyst Init.)	EPA 200.9 KW	EPA 200.7 KW

Sample #	Date Collected	Sample Location	Lead, mg/L	Copper, mg/L
01064401	6/26/2008	124 Riverhill Dr	<(0.001)	<(0.02)
01064402	6/26/2008	90 NE Mahonia	<(0.001)	<(0.02)
01064403	6/26/2008	101 NE Mahonia	0.002	<(0.02)
01064404	6/26/2008	171 Riverhill Ln	0.002	0.06
01064405	6/26/2008	122 Riverhill Ln	<(0.001)	<(0.02)
01064406	6/26/2008	91 Riverhill Ln	<(0.001)	0.02
01064407	6/26/2008	170 Riverhill Dr	<(0.001)	<(0.02)
01064408	6/26/2008	230 Mahonia Dr	0.001	0.05
01064409	6/26/2008	161 Riverhill Ln	<(0.001)	<(0.02)
01064410	6/26/2008	80 Riverhill Ln	<(0.001)	0.06

Division of Environmental Health
Office of Drinking Water

HELP



Main Report



1 / 2



100%

Pre - Adequacy Data Summary
As of: 08/03/2008Page 1 of 2
Report Date: 08/03/2008

Administrative Data

"Mailing Information:"
RIVERHILL HOMEOWNERS ASSN, 72810
KEN D LOOMIS
(360) 731-6444
PO BOX 86
Belfair, WA 98528

Ownership:
Owner Type...: Other
Owner Name.: RIVERHILL HOA

Last WFI Update: 7/13/2007

Group.....: A
Type.....: Comm
DOH Region ..: Southwest
County.....: MASON

Connections:

Active Connections.....: 86
Approved Connections.: See approved numbers - 100

Operating Permit Description

Current and Valid Operating Permit (Yes/No) - Yes

Permit Category Color.: Green
DOH Recommendation:

Green: Systems in this category are considered adequate for existing uses and new service connections up to the number of approved service connections.

Water Quality Violations

Incident Date	Severity
12/31/2007	Action Level

Operator Certification Requirement

In Compliance

Water System Plan Requirement

Not Required

Compliance Actions

Action	Status	Issue Date	Reason
*** No Current Compliance Actions Found ***			

Regional Staff Comments

Disclaimer

This is a DOH Pre - Adequacy Data Summary for this water system that is based on information available at this time. Other entities such as Local Building, Planning and Health Jurisdictions, or financial institutions have alternative authority to make final decisions involving development, building permits and financing.

IOC - LCR

IOC - LCR by EPA Methods 200.9, 200.7

Distribution System - Report of Analysis

IOC - LCR	Group: A
System ID No: 72810M	System Name: Riverhill Homeowners Asse
DOH Source No: 93	County: Mason
Sample Purpose: C	Date Received: 6/30/2008
	Date Analyzed: 7/10/2008
	Date Reported: 7/15/2008
Send Report To: Ken Loomis P.O. Box 86 Belfair, WA 98528	Bill To:

DOH #	Lead, mg/L	Copper, mg/L
SRL, mg/L	0.001	0.02
Trigger Level, mg/L	--	--
MCL, mg/L	*	*
Analytical Method (Analyst Init.)	EPA 200.9 KW	EPA 200.7 KW

Sample #	Date Collected	Sample Location	Lead, mg/L	Copper, mg/L
* SRL: Trigger Level: MCL: NA: ND: <(0.00x):	Lead has not been assigned an MCL, it has an 'Action Level' of 0.015 mg/L designated by EPA. Copper has not been assigned an MCL, it has an 'Action Level' of 1.3 mg/L designated by EPA. (State Reporting Level), indicates the minimum reporting level required by the Washington Department of Health (DOH). DOH Drinking Water response level. Systems with compounds detected at concentrations in excess of this level are required to take additional samples. Contact your regional DOH office for further information. (Maximum Contaminant Level), If the contaminant amount exceeds the MCL, immediately contact your regional DOH office. (Not Analyzed), in the results column indicates this compound was not included in the current analysis. (Not Detected), in the results column indicates this compound was analyzed and not detected at a level greater than or equal to the SRL. indicates the compound was not detected in the sample at or above the concentration indicated.			

87644

Page 2

IOC - LCR

IOC - LCR by EPA Methods 200.9, 200.7

Distribution System - Report of Analysis

IOC - LCR	Group: A
System ID No: 72810M	System Name: Riverhill Homeowners Assoc.
DOH Source No: 93	County: Mason
Sample Purpose: C	Date Received: 9/18/2007
	Date Analyzed: 9/26/2007
	Date Reported: 9/28/2007
Send Report To: Ken Loomis P.O. Box 86 Belfair, WA 98528	Bill To:

DOH #	Lead, mg/L	Copper, mg/L
SRL, mg/L	0.001	0.02
Trigger Level, mg/L	--	--
MCL, mg/L	*	*
Analytical Method (Analyst Init.)	EPA 200.9 NP	EPA 200.7 NP

Sample #	Date Collected	Sample Location	Lead, mg/L	Copper, mg/L
01044301	9/18/2007	124 Riverhill Dr	<(0.001)	<(0.02)
01044302	9/18/2007	90 NE Mahonia	3.95	16.9
01044303	9/18/2007	101 NE Mahonia	0.004	<(0.02)
01044304	9/18/2007	171 Riverhill Ln	<(0.001)	0.07
01044305	9/18/2007	122 Riverhill Ln	<(0.001)	0.03

*
SRL:
Trigger Level:
MCL:
NA:
ND:
<(0.00x):

Lead has not been assigned an MCL, it has an 'Action Level' of 0.015 mg/L designated by EPA. Copper has not been assigned an MCL, it has an 'Action Level' of 1.3 mg/L designated by EPA.
(State Reporting Level), indicates the minimum reporting level required by the Washington Department of Health (DOH).
DOH Drinking Water response level. Systems with compounds detected at concentrations in excess of this level are required to take additional samples.
Contact your regional DOH office for further information.
(Maximum Contaminant Level), If the contaminant amount exceeds the MCL, immediately contact your regional DOH office.
(Not Analyzed), in the results column indicates this compound was not included in the current analysis.
(Not Detected), in the results column indicates this compound was analyzed and not detected at a level greater than or equal to the SRL.
indicates the compound was not detected in the sample at or above the concentration indicated.