



STATE OF WASHINGTON
DEPARTMENT OF HEALTH
SOUTHWEST DRINKING WATER REGIONAL OPERATIONS
PO Box 47823, Olympia, Washington 98504-7823
TDD Relay 1-800-833-6388

November 2, 2009

Ken Loomis
Post Office Box 86
Belfair, Washington 98528

Subject: Riverhill Homeowners Association Water System, ID #72810M, Mason County;
Rescinding Corrosion Control Treatment Requirement and Future Lead/Copper
Monitoring

Dear Ken Loomis:

The lead and copper monitoring conducted by the above system in June 2008 and September 2009 demonstrated that the water is not corrosive and corrosion control treatment is not necessary. Since the results of these sample sets are below the lead and copper action levels, this system is considered optimized for corrosion control. This system is no longer required to pursue corrosion control treatment.

The next monitoring requirements for lead and copper are:

- Collect five samples between June 1 and September 30 every 3 years starting in 2012.

If there is an exceedance of either action level in the future, the treatment requirement for corrosion control will again become effective. In that case, we will provide additional direction.

The action level for lead is 0.015 milligrams per liter (mg/L) and for copper is 1.3 mg/L.

If you have questions, please contact us at (360) 236-3046.

Sincerely,

Belle Fuchs
Office of Drinking Water, Source Monitoring

Sophia Petro
Office of Drinking Water, Source Monitoring

cc: Jeromy Hicks, Riverhill Homeowners Association
Mason County Health District
Denise Garrett-Berry, ODW
Virpi Salo-Zieman, ODW
Cheri Paine, ODW

